

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.

7165-1521:114

Page 1 of 2

CATEGORY:

Control Unit (Non High-Rise)

LISTEE:

Siemens Building Technologies, Inc., 1000 Deerfield Parkway, Buffalo Grove, IL 60089
Contact: Ferd Orpano (847) 941-6176 FAX (866) 699-0238

DESIGN:

Models ALS3, ALS3R, ALS3-230, ALS3R-230 fire alarm control units. Power limited. Automatic, manual, coded, noncoded, local, auxiliary, remote station, *(DACT), *(reverse polarity), proprietary, *(multiplex), *central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

3-BPS/M, 3-BPS/M-230	Booster Power Supply
3-PPS/M, 3-PPS/M-230	Primary Power Supply
3-RS232	CPU RS232 Comm
3-XMEM	CPU Memory Option
3-IDC8/4	Zone Card
3-CPU	Central Processing Unit
3-LCD	CPU LCD Display
3-OPS	Off Premises Signaling Module
3-LDSM	LED Display Module
3-LRMF	Blank LRM Filler
3-CHAS4, -CHASS, -CHAS7	Module Chassis
3-CAB-5R-LG,-7R,-14R,-21R	Module Cabinet (red)
3-TAMP, 3-TAMP5	Tamper Switch
3-RCC7(R)-LG,-RCC14(R)-LG,-RCC21(R)-LG	Closet Cabinet (red)
3-PSMON	Power Supply Drive Monitor
3-BPMON	Power Supply Booster Monitor
3-24G,-24R,-24Y,-12RY,-12SY,-12SR,-12SG	LED Display
3-12/R,Y,-12/2Y,-12/S2Y,-12/S1GY	LED Display
3-12/S1RY, -6/3S1G2Y	LED Display
3-6/3S1GYR, -6/3S3L	LED Display
3-CAB5BR	Enclosure
3-SSDC	Single Loop Controller Module
3-SDC	Signature Data Card
3-RS485	Network Communication Card
3-RS485A, 3-RS485B, 3-RS485R	Network Communication Card
3-DSDC	Dual Loop Controller Module
3-FIB, 3-FIBA	Fiber/Copper Data Communication Module
3-AADC	Analog Addressable Communication Module
3-ATPINT	ATPC Interface Module
3-REMIC, 3-REMICP	Remote Microphone
3-ZA90, 3-ZA20A, 3-ZA20B	Zone Amplifier
3-ZA-40A, 3-ZA40B	

RATING: ALS3, ALS3R: 120 VAC
ALS3-230, ALS3R-230: 220 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal.

NOTE: For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1591:186

*Rev. 01-13-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 23, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager